



PARSHALL FLUME

96 INCH FLOW CHART

Head (ft)	CFS	GPM	MGD
0.01			
0.05			
0.10			
0.15			
0.20			

Head (ft)	CFS	GPM	MGD
1.25	45.8	20560	29.6
1.30	48.78	21890	31.53
1.35	51.83	23260	33.5
1.40	54.95	24660	35.52
1.45	58.14	26090	37.58
1.50	61.39	27550	39.68

0.25	3.449	1548	2.229
0.30	4.623	2075	2.988
0.35	5.922	2658	3.827
0.40	7.339	3294	4.743
0.45	8.869	3980	5.732

1.55	64.72	29040	41.83
1.60	68.1	30560	44.02
1.65	71.56	32110	46.25
1.70	75.07	33690	48.52
1.75	78.65	35300	50.83

0.50	10.5	4715	6.789
0.55	12.24	5495	7.913
0.60	14.08	6320	9.101
0.65	16.01	7187	10.35
0.70	18.04	8096	11.66

1.80	82.29	36390	53.19
1.85	86	38600	55.58
1.90	89.76	40290	58.02
1.95	93.59	42000	60.49
2.00	97.48	43750	63

0.75	20.15	9045	13.03
0.80	22.36	10030	14.45
0.85	24.64	11060	15.93
0.90	27.02	12120	17.46
0.95	29.47	13230	19.05

2.05	101.4	45520	65.55
2.10	105.4	47320	68.14
2.15	109.5	49140	70.76
2.20	113.6	50990	73.43
2.25	117.8	52860	76.13

1.00	32	14360	20.68
1.05	34.61	15530	22.37
1.10	37.3	16740	24.1
1.15	40.06	17980	25.89
1.20	42.89	19250	27.72

2.30	122	54760	78.86
2.35	156.3	56690	81.64
2.40	130.7	56840	84.45
2.45	135.1	60620	87.29
2.50	139.5	62620	90.17

Virtual Polymer Compounds | VPC Fiberglass

vpcfiberglass.com **P 585.735.9668 F 585.735.9965**

2410 N. FOREST RD · SUITE 301 · GETZVILLE, NY 14068